

CERTIFICATE OF COMPLIANCE

Certificate Number R9483
Report Reference R9483-1991-10-15
Issue Date 2023-10-17

Issued to: HANCHETT ENTRY SYSTEMS INC
10027 S 51st St, Suite 102
Phoenix, AZ 85044 United States

This certificate confirms that representative samples of Electric Strikes
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 10B, Fire Tests of Door Assemblies, Edition 10
UL 10C, Positive Pressure Fire Tests of Door Assemblies, Edition 3

Additional Information: See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number	R9483
Report Reference	R9483-1991-10-15
Issue Date	2023-10-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Electric strike, Models 1003, 1004, 1006, HT 1006 with optional alpha or alphanumeric suffixes, for use with cylindrical and mortise latches having 1/2, 5/8 or 3/4 in. bolts. The Model 1006 may be used with single doors measuring 48 in. wide and 96 in. high for durations up to and including 3 hr, and with pairs of doors measuring 96 in. wide and 96 in. high for durations up to and including 1-1/2 hr.

Electric strike, Models 7501, 7505, 7506/LH, 7506/RH, with optional suffix "LBM", for use with cylindrical and mortise latches having 5/8 or 3/4 in latch bolts.

Electric strike, 4500 Series for use with mortise type latches having 3/4 in. latch bolts.

Electric strike, 8500 Series for use with mortise type latches having 3/4 in. latch bolts.

|



Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>

